Product Bulletin

TOTO®

January 27, 2023 • Volume 2023 • Issue 01

Plumbing Fixture Restrictions

Dear Valued TOTO Customer:
Please see the details below of the current legislation and regulatory updates for states with installation restrictions based on water consumption limits.
Previously published in Jan. 2021 (PB#21-01), **Addition to this revised file is for NY, effective 6/26/23.**

Regulation	Effective Date	Water Closets	Urinals	Lavatory Faucets	Showerheads	Kitchen Faucets	New Construction All Sales	Allow Dual Flush HET
National, EPAct '92	1994	1.6 gpf	1.0 gpf	2.2 gpm	2.5 gpm	2.2 gpm	All Sales	NA
National, WaterSense*	2007	1.28 gpf	0.5 gpf	1.5 gpm	2.0 gpm	NA	Voluntary	Y
Arizona, Scottsdale	1/1/2017	1.28 gpf	0.5 gpf	1.5 gpm	2.0 gpm	2.2 gpm	New Construction	Y
California**	1/1/2016	1.28 gpf***	0.125 gpf wall mounted, 0.5 gpf^^^ others	Public 0.5 gpm / 0.25 gpc, Residential 1.2 gpm^^	1.8 gpm***/^^	1.8/2.2 gpm^^^^	All Sales	Y
California, West Hollywood	1/1/2020	1.1 gpf***	0.125 gpf wall mounted, 0.5 gpf^^^ others	Public 0.5 gpm / 0.25 gpc, Residential 1.2 gpm	1.5 gpm***	1.5/2.2 gpm	New Construction	Y
Colorado** (see Notes 2 & 7)	9/1/2016 and 1/1/2021	1.28 gpf***	0.5 gpf***	Public – 0.5 gpm / Residential – 1.5 gpm***	2.0 gpm***	1.8/ 2.2 gpm^^^^	All Sales	Y
Colorado, Boulder	2/1/2017	Same as Colorado	Same as Colorado	Public – 0.5 gpm Residential – 1.5 gpm***	Same as Colorado	1.5 gpm	New Construction	Y
Colorado, Fort Collins (see Note 5)	1/12/2019	Same as Colorado	Same as Colorado	Same as Colorado	1.8 gpm***	1.8 gpm	New Construction	Y
Florida, Broward	6/1/2012	1.28 gpf	0.5 gpf	1.5 gpm	2.0 gpm	2.2 gpm	New Construction	Y
Florida, Miami-Dade	1/1/2009	1.28 gpf***	0.5 gpf***	1.5 gpm***	1.5 gpm^	1.5 gpm	New Construction	Y
Georgia****	7/1/2012	1.28 gpf***	0.5 gpf***	1.5 gpm***	2.5 gpm	2.0 gpm	All Sales	Y
Hawaii	1/1/2021	EPAct '92	EPAct '92	Public – 0.5 gpm Residential – 1.2 gpm	1.8 gpm	1.8/2.2 gpm^^^^	All Sales	Y
Illinois, Chicago (see Note 3)	11/18/2014	1.28 gpf***	0.5 gpf***	1.5 gpm***	2.0 gpm***	NA	New Construction	Y
Maryland, Rockville	7/1/2012	1.28 gpf	0.5 gpf	1.5 gpm	2.0 gpm	1.5 gpm	New Construction	Y
Massachusetts (see Note 11)	1/1/2020	1.28 gpf	0.5 gpf	1.5gpm	2.0 gpm	1.8/2.2 gpm^^^^	All Sales	Y
Nevada (see Note 8)	1/1/2020	1.28 gpf***	0.5 gpf***	1.5 gpm***	2.0 gpm***	NA	New Construction	Y
New York	1/1/2022	1.28 gpf***	0.5 gpf***	1.5 gpm***	2.0 gpm***	2.2 gpm	All Sales	Y
New York	6/26/2023 (supercedes above)	1.28 gpf***	0.125 gpf wall mounted, 0.5 gpf^^^ others	Public 0.5 gpm / 0.25 gpc, Residential 1.2 gpm	1.8 gpm***	1.8/2.2 gpm^^^^	All Sales	Y
Oregon (See Note 9)	10/1/2020	1.6 gpf	0.5 gpf	1.5 gpm	2.0 gpm	1.8/2.2 gpm^^^^	New Construction	Y
Oregon (see Note 10)	1/1/2022	1.6 gpf	0.5 gpf	1.2 gpm	1.8 gpm	1.8/2.2 gpm^^^^	All Sales	Y
Texas** (See Note 1)	1/1/2014	1.28 gpf***	0.5 gpf***	EPAct '92	EPAct '92	EPAct '92	All Sales	Y
Vermont**	7/1/2021	EPACT 92	0.5 gpf	Public - 0.5 gpm Residential - 1.5 gpm	2.0 gpm	1.8/2.2 gpm^^^^	All Sales	Y
Washington, D.C.	3/28/2014	1.28 gpf***	0.5 gpf***	1.5 gpm***	2.0 gpm***	2.2 gpm	New Construction	Y
Washington (see Note 6)	1/1/2021	1.28 gpf	Wall - 0.125 gpf Other Types - 0.5 gpf	Public – 0.5 gpm Residential – 1.2 gpm	1.8 gpm	1.8/2.2 gpm^^^^	All Sales	Y

Note 4 removed—replaced with notes 9 & 10

888-295-8134
www.totousa.com
© 2023 TOTO U.S.A.

Plumbing Fixture Restrictions

On occasion, TOTO may ship certain of its products into areas or territories which are subject to the restrictions contained herein but only does so with the expectation that the purchaser / end user has accepted responsibility pursuant to any and all applicable federal, state, local or other governmental laws and regulations regarding the purchase, resale or installation for such TOTO products. EPA WaterSense may be required in new construction and permitted remodel per local code or city ordinance. Check local codes for requirements.

This is a summary of high profile code changes and may not represent all local jurisdictions. Please consult your local codes for additional requirements.

* TOTO USA is a WaterSense partner.

** TOTO USA supported legislation.

*** WaterSense certified

^ Or WaterSense certified products

**** The GA law establishes these levels for new construction but notes that the WC levels are for all sales.

Note 1: Texas HB 2667 exempts flushometer and wall-mounted water closets from this requirement.

^^ For residential lavatory faucets:

- Maximum 2.2 gpm at 60 psi – Manufactured prior to September 1, 2015.
- Maximum 1.5 gpm at 60 psi – Manufactured on or after September 1, 2015 and prior to July 1, 2016.
- Maximum 1.2 gpm at 60 psi – Manufactured on or after July 1, 2016.

For showerheads:

- Maximum 2.0 gpm at 80 psi - Manufactured after July 1, 2016 and prior to July 1, 2018.
- Maximum 1.8 gpm at 80 psi – Manufactured after July 1, 2018.
- All showerheads shall have a minimum flow rate of 60 percent of the maximum flow rate at 20 psi.
- All showerheads shall have a minimum flow rate of 75 percent of the maximum flow rate at 45 psi.

Note 2: CO SB-103 only applies to lavatory faucets, showerheads, flushing urinals and tank-type water closets.

^^^ City of Los Angeles requires all urinals to have a maximum flush volume of 0.125 gpf for new construction.

Note 3: This applies to new construction in the greater Chicago area (more specifically those in Illinois that obtain their water from Lake Michigan).

Note 5: Requirements include: minimum MaP Score of 600 for all water closets; maximum flow rate of 1.8 gpm for all showerheads except for those installed in institutional and educational occupancies (e.g. hospitals, assisted living facilities, K-12 schools); and maximum flow rate of 0.5 gpm for private lavatory faucets installed in non-residential occupancies except institutional (e.g. hospitals, assisted living facilities).

^^^^ Maximum flow rate is 1.8 gpm with optional temporary flow of 2.2 gpm.

Note 6: Effective sale date applies to all products manufactured on or after January 1, 2021.

Note 7: For the following products sold on or after January 1, 2021: residential kitchen faucets shall have a maximum flow rate of 1.8 gpm with an optional temporary flow of 2.2 gpm; public lavatory faucets shall have a maximum flow rate of 0.5 gpm; and flushometer- valve water closets shall be certified to the EPA WaterSense Program.

Note 8: According to the main proponents of NV AB 163 (Assemblyman Howard Watts and Senator Chris Brooks), the January 1, 2020 effective date only applies to new installations. Local governments are responsible for updating their building codes or ordinances to enforce the requirements of NV AB 163 and not a state agency. Furthermore, based on the Nevada Revised Statutes (NRS) 278.582 – Section 1, local governments are supposed to eventually update their ordinances to address product sales as well. There is no deadline indicated within NV AB 163 or NRS 278.582 for when this is to occur.

Note 9: Water closets that are in a "remote location" can have a maximum flush volume of 1.6 gpf. "Remote location" is defined as "a water closet located not less than 30 feet (9144 mm) upstream of the nearest drain line connections or fixtures, and is located where less than 1.5 drainage fixture units are upstream of the water closet drain line connection." If the remote location" determination is not authorized, 1.28 gpf shall be the maximum.

Note 10: Executive Order approved by Governor. Effective sale date applies to all showers, residential and public faucets manufactured on or after January 1, 2022

Note 11: Note 11: Per Massachusetts S 9, effective date applies to products for sale on or after January 1, 2022

Disclaimer of Liability and Indemnification.

Neither TOTO USA, Inc. nor any TOTO affiliated companies (collectively, "TOTO") shall be held liable for any improper or incorrect use of the information described and/or contained herein and assumes no responsibility for anyone's use of the information. In no event shall TOTO be liable for any direct, indirect, incidental, special, exemplary, or consequential damages as a result of any purchaser or third parties' interpretation or application of any information herein. All purchasers and third party end users of any TOTO products are solely responsible for adhering to and complying with any and all federal, state, local and any other governmental authority or municipality laws, restrictions or regulations related to the sale, purchase, installation and use of TOTO products and do therefore agree to defend, indemnify, and hold harmless TOTO, its officers, directors, employees, representatives and agents from any damages, fines, suits, penalties, etc. related to any improper acts, violations or non-compliance with such laws and regulations.

© 2023 TOTO U.S.A.